

Confirmation

LEED v4.1

On 8 June 2020, Eurofins Product Testing A/S received a sample of paint representative for:

KRAFT MASTER

supplied by

Druckfarben Hellas S.A.

The tested sample was supplied as being a worst-case representative for the abovementioned product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, ISO 11890-2 testing standards in the latest versions (See Indoor Air Comfort certification no. IAC-348-01-01 and test report no. 392-2020-00090604_B_EN and no. 392-2020-00251001_XI_EN).

The test results of the tested sample indicate that this product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of Option 2 of LEED v4.1 BETA (July 2019) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below 1 and having a TVOC according to EN 16516 below 0.5 mg/m³ and a formaldehyde emission below 10 µg/m³ after 28 days.


VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of the EU Decopaint Directive 2004/42/CE.

28 July 2020



Peter Alexander Skov
Analytical Chemist, MSc. Eng. Chemistry



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.